



Ref. Certif. No.

SG SGS-00497

**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)
CB SCHEME**

CB TEST CERTIFICATE

Product

Photovoltaic (PV) Module(s)

Name and address of the applicant

PROMOD ENERJİ ÜRETİM SAN VE TİC A.Ş.
Kayseri O.S.B. Mah. 29. Cad. No.27 Melikgazi, KAYSERİ, Türkiye

Name and address of the manufacturer

PROMOD ENERJİ ÜRETİM SAN VE TİC A.Ş.
Kayseri O.S.B. Mah. 29. Cad. No.27 Melikgazi, KAYSERİ, Türkiye

Name and address of the factory

Note: When more than one factory, please report on page 2

PROMOD ENERJİ ÜRETİM SAN VE TİC A.Ş.
Kayseri O.S.B. Mah. 29. Cad. No.27 Melikgazi, KAYSERİ, Türkiye
☒ Additional Information on page 2

Ratings and principal characteristics

Max. System voltage: 1500V
Maximum Over-current Protection: 25A/30A/35A

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

-

Model / Type Ref.

See page 2

Additional information (if necessary may also be reported on page 2)

-
☐ Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 61215-1:2021, IEC 61215-2:2021, IEC 61215-1-1:2021
IEC 61730-1:2023, IEC 61730-2:2023

As shown in the Test Report Ref. No. which forms part of this Certificate

GCTC2024WT0158-01-02, GCTC2024WT0158-02-02

This CB Test Certificate is issued by the National Certification Body

SGS Testing & Control Services Singapore Pte Ltd
30 Boon Lay Way
#03-01 Singapore 609957

Date: 12/10/2024

Signature:

Andrew Zhai
Certifier



Ref. Certif. No.

SG SGS-00497

Name and address of the factory

N/A

Additional information

Model/Type reference

PRDxxx-120MTN (xxx=385-415, in steps of 5, 120 cells, 1/3 cut)

PRDxxx-108MT (xxx=440-460, in steps of 5, 108 cells, 1/2 cut)

PRDxxx-110MT (xxx=525-570, in steps of 5, 110 cells, 1/2 cut)

PRDxxx-120MT (xxx=620-645, in steps of 5, 120 cells, 1/2 cut)

PRDxxx-132MT (xxx=650-710, in steps of 5, 132 cells, 1/2 cut)

SGS

Date: 12/10/2024

Signature:

Andrew Zhai
Certifier